

Energy performance certificate (EPC)

2, Thomas Street
Porthleven
HELSTON
TR13 9DG

Energy rating

E

Valid until:

4 August 2029

Certificate number:

8081-6328-6500-7855-9906

Property type

End-terrace house

Total floor area

59 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is E. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		77 C
55-68	D		
39-54	E	41 E	
21-38	F		
1-20	G		

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property’s age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Roof	Roof room(s), insulated	Good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, LPG	Very poor
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Very poor
Lighting	Low energy lighting in 64% of fixed outlets	Good
Roof	(another dwelling above)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO2. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Solar photovoltaics

Primary energy use

The primary energy use for this property per year is 102 kilowatt hours per square metre (kWh/m2).

Additional information

Additional information about this property:

- Stone walls present, not insulated
 - Dwelling may be exposed to wind-driven rain
-

How this affects your energy bills

An average household would need to spend **£1,262 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £598 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2019** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 8,398 kWh per year for heating
 - 1,839 kWh per year for hot water
-

Impact on the environment

This property's environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 1.7 tonnes of CO₂

This property's potential production 0.2 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Internal wall insulation	£4,000 - £14,000	£383
2. Floor insulation (solid floor)	£4,000 - £6,000	£68
3. Low energy lighting	£20	£13
4. Solar water heating	£4,000 - £6,000	£93
5. Heat recovery system for mixer showers	£585 - £725	£17
6. High performance external doors	£1,000	£25

Advice on making energy saving improvements

[Get detailed recommendations and cost estimates \(www.gov.uk/improve-energy-efficiency\)](http://www.gov.uk/improve-energy-efficiency)

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: [Warm Homes Local Grant \(www.gov.uk/apply-warm-homes-local-grant\)](http://www.gov.uk/apply-warm-homes-local-grant)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme \(www.gov.uk/apply-boiler-upgrade-scheme\)](http://www.gov.uk/apply-boiler-upgrade-scheme)
- Help from your energy supplier: [Energy Company Obligation \(www.gov.uk/energy-company-obligation\)](http://www.gov.uk/energy-company-obligation)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Lester Raymond
Telephone	01736 331688
Email	nick4epc@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/004498
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	5 August 2019
Date of certificate	5 August 2019
Type of assessment	RdSAP
